

Kursfortegnelse +VG

Nett: 230V IT-nett

Kurs nr:	Beskrivelse:	Vern:	Tverrsnitt:	Forlegning
1	Hovedvern	3/125A	PFSP 3x95AL+j	E
2	Ventilasjonsanlegg	3/63A	PFSP 3x16mm ²	E
3	Lys Gang 101, WC, garderobe D&H, Arkiv 110	2/10A	PR 2x1,5mm ²	E/A1
4	Stikk Gang 101, garderobe D&H, Arkiv 110	2/10A	PR 2x1,5mm ²	E/A1
5	Lys kontor 111, 112	2/10A	PR 2x1,5mm ²	E/A1
6	Lys kontor 113, 114	2/10A	PR 2x1,5mm ²	E/A1
7	Stikk kontor 111, 112	2/10A	PR 2x1,5mm ²	E/B1
8	Stikk kontor 113, 114	2/10A	PR 2x1,5mm ²	E/B1
9	Varmeovner kontor 111, 112	2/16A	PR 2x2,5mm ²	E/B1
10	Varmeovner kontor 113, 114	2/16A	PR 2x2,5mm ²	E/B1
11	Styrestrøm	2/10A	Internt	
K11.1	Kontaktor varme kontor 111		PN 2x1,5mm ²	
K11.2	Kontaktor varme kontor 112		PN 2x1,5mm ²	
K12.1	Kontaktor varme kontor 113		PN 2x1,5mm ²	
K12.2	Kontaktor varme kontor 114		PN 2x1,5mm ²	
T11.1	Termostat kontor 111		PN 2x1,5mm ²	
T11.2	Termostat kontor 112		PN 2x1,5mm ²	
T12.1	Termostat kontor 113		PN 2x1,5mm ²	
T12.2	Termostat kontor 114		PN 2x1,5mm ²	
12	Tilførsel brannsentral (alarmsentral)	2/10A	PR 2x1,5mm ²	C
13	Lys trapp	2/10A	PR 2x1,5mm ²	C
14	Lys Gang 201, WC, garderobe D&H, Arkiv 210	2/10A	PR 2x1,5mm²	E/A1
15	Stikk Gang 201, garderobe D&H, Arkiv 210	2/10A	PR 2x1,5mm²	E/A1
16	Lys kontor 211, 212	2/10A	PR 2x1,5mm²	E/A1
17	Lys kontor 213, 214	2/10A	PR 2x1,5mm²	E/A1
18	Stikk kontor 211, 212	2/10A	PR 2x1,5mm²	E/B1
19	Stikk kontor 213, 214	2/10A	PR 2x1,5mm²	E/B1
20	Varmeovner kontor 211, 212	2/16A	PR 2x2,5mm²	E/B1
21	Varmeovner kontor 213, 214	2/16A	PR 2x2,5mm²	E/B1
22	Styrestrøm	2/10A	Internt	
K21.1	Kontaktor varme kontor 211		PN 2x1,5mm²	
K21.2	Kontaktor varme kontor 212		PN 2x1,5mm²	
K21.3	Kontaktor varme kontor 213		PN 2x1,5mm²	
K21.4	Kontaktor varme kontor 214		PN 2x1,5mm²	
T21.1	Termostat kontor 211		PN 2x1,5mm²	
T21.2	Termostat kontor 212		PN 2x1,5mm²	
T21.3	Termostat kontor 213		PN 2x1,5mm²	
T21.4	Termostat kontor 214		PN 2x1,5mm²	